



APPLICATION

LFD model is designed to be used in clean space environments such as medical facilities (pharmaceutical / biotechnology industry), research industries (semiconductors, aerospace industries), hospital operating and clean rooms.

LFD have low aspiration characteristics resulting in rapid temperature and velocity equalization of air mass into the zone of occupancy.

FEATURED STANDARD CONSTRUCTION

- **OUTER FRAME**

- Constructed from 20 Ga galvanized steel sheets with punched corners.

- **FACE**

- Constructed from 4 mm hole diameter perforated galvanized steel sheets.

- **FILTER FIXATION**

- Normal Steel Clamp.

- **SIZES**

- Available sizes are: $\left. \begin{matrix} 24" \times 24" \\ 36" \times 24" \\ 48" \times 24" \end{matrix} \right\}$ or $\left. \begin{matrix} 600\text{mm} \times 600\text{mm} \\ 900\text{mm} \times 600\text{mm} \\ 1200\text{mm} \times 600\text{mm} \end{matrix} \right\}$

- **FINISH**

- RAL 9010 White Finish.



OPTIONS

- 16 Ga Galvanized Steel construction.
- 1 and 1.5 mm Stainless Steel 304 construction.
- 1 and 1.5 mm Stainless Steel 316 construction.
- 1 and 1.5 mm Aluminum construction.
- Aluminum, Stainless Steel 304 and Stainless Steel 316 perforated sheets for the face.
- 3 cm extruded Aluminum flange for Aluminum and Galvanized construction for T-bar mount.
- 3 cm Stainless Steel duct flange for Stainless Steel construction for T-bar mount.
- HEPA filter H13 (99.95% degree of arrestance) or H14 (99.995% degree of arrestance) grade.
- Stainless Steel handle for filter fixation.

N.B: A 0.5 cm clearance is deducted from your order size.


For more information please consult our engineers.

Tests Conducted in accordance with ASHRAE Standard 70-2006 in ETL-ETS USA

Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.

ILLUSTRATIONS

Non-Welded



All Older Sizes	Number of Inlet	Round Neck (mm)	H (mm)	
			LFDW200	LFDW100
	1	250	200	150

N.B: A 0.5 cm clearance is deducted from your order size.

For more information please consult our engineers.

Tests Conducted in accordance with ASHRAE Standard 70-2006 in ETL-ETS USA

Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.


ILLUSTRATIONS

Non-Welded


24"x24" or 600mm x 600mm

LFD200: Construction of LFD with filter support

Note: Fit for KBE proposed hepa filters only



LFD100: Construction of Diffuser without filter support



N.B: A 0.5 cm clearance is deducted from your order size.

For more information please consult our engineers.

Tests Conducted in accordance with ASHRAE Standard 70-2006 in ETL-ETS USA

Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.


ILLUSTRATIONS

Non-Welded


36"x24" or 900mm x 600mm

LFD200: Construction of LFD with filter support

Note: Fit for KBE proposed hepa filters only



LFD100: Construction of Diffuser without filter support



N.B: A 0.5 cm clearance is deducted from your order size.

For more information please consult our engineers.

Tests Conducted in accordance with ASHRAE Standard 70-2006 in ETL-ETS USA

Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.


ILLUSTRATIONS

Non-Welded


48"x24" or 1200mm x 600mm

LFD200 : Construction of LFD with filter support

Note: Fit for KBE proposed hepa filters only



LFD100 : Construction of Diffuser without filter support



N.B: A 0.5 cm clearance is deducted from your order size.

For more information please consult our engineers.

Tests Conducted in accordance with ASHRAE Standard 70-2006 in ETL-ETS USA

Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.



LAMINAR FLOW DIFFUSER

LFD/LFDW Series

PERFORMANCE DATA

Unit Size (In.)	Ak Factor (Ft ²)	Velocity (Cfm/ft ²)	20	30	40	50	60	70	80
24x 24 Neck Size Diam 10''	2.03	Airflow	80	120	160	200	240	280	320
		SP.	0.001	0.003	0.005	0.008	0.012	0.016	0.021
		NC	<15	<15	<15	<15	<15	<15	<15
		A.V (Fpm)	30	44	58	71	82	92	101
36 x 24 Neck Size Diam 10''	2.95	Airflow	120	180	240	300	360	420	480
		SP.	0.002	0.005	0.008	0.013	0.019	0.026	0.034
		NC	<15	<15	<15	<15	<15	16	22
		A.V (Fpm)	31	42	56	68	79	88	99
48 x 24 Neck Size Diam 10''	3.45	Airflow	160	240	320	400	480	560	640
		SP.	0.003	0.007	0.012	0.018	0.028	0.036	0.047
		NC	<15	<15	<15	<15	20	24	31
		A.V (Fpm)	31	43	56	65	78	87	97

Notes:

- 1- Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.
- 2- Tests Conducted in accordance with ASHREA Standard 70-2006 (sound tests are conducted at Isothermal conditions).
- 3- Ak: Free area in ft²
- 4- Airflow in Cfm
- 5- S.P: Static pressure is in Inch of Water. SP was measured at 1.5 duct diameters upstream of the inlet of the Diffuser.
- 6- Cfm/Ft²: Airflow rate through diffuser per square foot of overall face area.
- 7- NC: Noise Criteria is based on a 10db room attenuation.
- 8- A.V: Average Velocity at 6 feet below ceiling.
- 9- Test data shown is for a temperature difference DT of 5°F between the supply air temperature and the average room air temperature.
- 10- Test Room Dimensions: 18'x24'x9'



LAMINAR FLOW DIFFUSER

LFD/LFDW Series

LEAKAGE DATA

The purpose of test was to define the leakage of the Filter gasket and the Laminar casing when filter is block by Dust. The perimeter seal and casing around the filter was the leakage component.

Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating". The test samples were not dampers but filters with the outlet side blocked with cardboard and taped. Air Volume was measured employing metering stations containing appropriately sized orifice plates.


Test conducted at Intertek Lab under report No. 103197431.

AIR LEAKAGE RESULT:

MODEL LFD200-24x24, HEPA Filter H14

Pressure Drop Across Blocked Sample		Air Volume	
<u>in. Wg.</u>	<u>kPa</u>	<u>SCFM</u>	<u>L/s</u>
0.5	0.124	0.8	0.4
1.0	0.249	1.3	0.6
1.5	0.373	1.8	0.8
2.0	0.498	2.2	1.0
2.5	0.622	2.6	1.2
3.0	0.747	2.9	1.4

GRAPHICAL TEST RESULTS



ORDER INFORMATION

MODEL BOX PERFORATED FLANGE FILTER FIXATION ORDER SIZE



<p>↑</p> <p>-LFD200: Construction of LFD with filter support. -LFD100: Construction of Diffuser without filter support</p>	<p>↑</p> <p>--: Galvanized (available for Galvanized construction only) SCP: Stainless Steel 304 16SCP: Stainless Steel 316 ALP: Aluminum (available for Galvanized & Aluminum construction)</p>	<p>↑</p> <p>--: Standard Clamp SSH: Stainless Steel lock</p>	<p>↑</p> <p>24"x24" 36"x24" 48"x24"</p>	<p>↑</p> <p>OR</p> <p>600mm x 600mm 900mm x 600mm 1200mm x 600mm</p>
<p>↑</p> <p>--: 20 Ga Galvanized Steel (STD) 16: 16 Ga Galvanized Steel SC10: 1 mm Stainless Steel 304 SC15: 1.5 mm Stainless Steel 304 16SC10: 1 mm Stainless Steel 316 16SC15: 1.5 mm Stainless Steel 316 AL10: 1 mm Aluminum AL15: 1.5 mm Aluminum</p>	<p>↑</p> <p>--: No Flange (STD) F : with 3 cm extruded aluminum flange for AL and GI construction OR 3 cm stainless steel duct flange for SS construction</p>			

N.B: A 0.5 cm clearance is deducted from width and height order size.
For more information, please check the submittal sheet.

Tests Conducted in accordance with ASHRAE Standard 70-2006 in ETL-ETS USA
Leakage tests were conducted in accordance with AMCA Standard 500-D-2012 entitled, "Laboratory Methods for Testing Dampers for Rating" ETL-ETS USA.