



INSTALLATION INSTRUCTION FIRE SMOKE DAMPER

FOR GRILLE MOUNTING ASSEMBLY

Installation Details

Model KFSD-111, KSD-333 & KFD-555 with sleeve that terminate at a grille, has to follow the below installation instruction.

Sleeve can be ended with flange shape with exact countersunk screwholes from KBE can be provided or a reverse retaining angle should be installed. Damper is offset in the sleeve to accommodate a single or double deflection grille

Model KFSD-111 & KFD-555 Maximum single unit 36" wide x 36" height or 30" Wide x 36" height

Model KSD-333 Maximum single unit 36" wide x 48" height

Model KCFSD -222 Maximum single unit 24" wide x 24" height

